FOR MYSORE STATE

4-11-49.

Public works (1951) Department.

G.O. SERIES.

G.O. No. 68

68

Dated 12-1-51

Close

[Despatch Abstract.]

ELECTRICITY - Restriction and Control - Mangalore Electric Licence

Supply to all kinds of load - permitted.

PUBLIC WORKS DEPARTMENT.

From.
Sri K.V.Karantha, M.A., M.I.E.,
Chief Electrical Inspector to Govt.,
Post Box No.417, Madras-5.

To:
The Secretary to Government,
Public Works Department,
Fort St. George, Madras.

No. 26. T/Mng/51-1, dated 4.1.51.

Sir,

Sub: Electricity - Restriction and control - Supply to M/s Sowrajan Tile Works, Mangalore for an additional load of 7.5 H.P.

Ref: Application No. Lan/5541/47/3, dated 18.12.50 from the licensee to Chief Electrical Inspector to Government.

The Mangalore licensee's application for supply to M/s Sowrajan Tile Works, Mangalore for an additional load of 7.5 H.P. for working the presses in their tile factory is forwarded to Government herewith in duplicate for necessary orders as the additional load is likely to cause the maximum demand in the service to exceed the limit of 50 KWs. As the earlier application made in January 1948 is for a load of 30 HP while he is at present satisfied with a load of 7.5 H.P. only against that application, supply to the additional load of 7.5 H.P. may please be sanctioned subject to the following conditions.

1) Supply to the additional load is availed of between 8 A.M. and 6 P.M.

P.T.O.

and (2) supply is liable to be required to be suitably regulated, stopped or cut off altogether as the case may be, if the power position or any other emergency in the Power house warrants such a course of action.

Yours faithfully,

Encl: 2.

Chief Elect. Inspector to Govt.

ADK 5/1

P.W.D (P)

66/12/11

C.No. 127 P/51.

Subj:- Elecy - R+C - Mangalore Electric Supply Co. Ltd - Supply to additional load permitted.

Ref:- From the CEIG. No. 26K/R+C/51-1 dt 4-1-51 / Govt. Rt No. 68 dt 12-1-51

H.E. the Governor of Madras hereby permits the Mangalore Electric Supply Co. Ltd to supply elecy to the Sovereign Tile works, Ltd Bockapatna, Mangalore for an addl load of 7.5 H.P. for working the presses in this tile factory as in the application for permit enclosed subject to the conditions that:

(1) Supply to the addl load is availed of only between 8 A.M and 6 P.M. and

(2) Supply is liable to be required to be suitably restricted staggered or cut off altogether

2/6

as the case may be, if the power position or any other emergency in the power house warrants such a course of action.

9-1-5 10-1-51.

10/1/51

Dated 19/1/51

To

The Resident Engineer, Mangalore Electric Supply Co Ltd Mangalore

(with one spare in original)

The CEIG.

NOTE The draft order on pp 1-2 above is submitted w.r.t the recommendation of the CEIG on pp 1-2 of ~~D.O. may be before issue~~.

9-1-5 10-1-51.

10/1/51

$.ON
1
11/5-1

2372

Ref.No.Man/2859/67/3 Dated 30th November 1950. - 13 P.L.

19-12.

The Mangalore Electric Supply Company, Limited,

Lf 30822

Application for permit for Electric Supply for prospective consumers whose requirements are 50 K.W. and less

1.	Name of Electric Supply Undertaking.	The Mangalore Electric Supply Co., Ltd.
2.	Registered Address.	No. 14, Old Court House Street, Calcutta.
3.	Name & Reg. Address of Consumer.	The Sovereign Tile Works, Ltd., Bockapatna.
4	Premises for which supply is required and its address.	~~Residential~~/Industrial/~~Public Building~~.
5.	Present maximum demand (if any)	0.530 K.W.(Lighting) 50 H.P. (Power)
6.	Estimated additional maximum demand required by consumer and for which application is now being made.	7.5 H.P. ~~K.W.~~ (connected)
7.	Is it practicable to arrange the consumer's operation so that the demand in (6) will not occur during the peack load period of the undertaking.	Yes (as this will be worked for ½ day only)
8.	By how much is it estimated that the (undertaking's) maximum demand will increase by the proposed consumer's load.	Nil K.W.
9.	Connected load to be installed.	Lighting ..... Motors 7.5 H.P.Phers
10.	Industry to be served (indicate the product to be manufactured and whether this is expansion of present production or new products.)	It is requested that permission to instal one 7.5 H.P. motor to work the presses in the tile factory, may be granted
11.	Is factory to work one, two or three shifts per day.	8 A.M. to 6 P.M.
12.	If consumer's plant is ready to take supply, give date when it was ready for supply, if not, state when it will be ready.	As soon as sanction is received.
13.	If products are orders of Department of supply please specify and attach as evidence copy of letter from department concerned.	For The Sovereign Tile Works Ltd., For Sujir Krishnayya Nayak & Sons. Partner, Managing Agents. Signature of Consumer.
	Remarks of supply undertaking.	
14.	(a) Capacity of exisiting service connection (if any).	100 amps 3 phase.
	(b) Is required service D.C. or A.C. High or low voltage.	A.C. 400 Volts 3 Phase
	(c) Brief list of main materials required for service connection.	Meter Board Cutouts Superite cable GI Pipe GI Wire BC Wire } Entire service exist

(d) Approximate cost of giving service.	Rs. Nil.
(e) Are all materials available in the stores for the undertaking.	
(f) What prime movers (if any) will be displaced by giving supply of electric power. Give type and condition of any such engines which would be displaced.	None
(g) Any other remarks by the undertaking on effect of this service on the system.	The application may be sanctioned between the hours of 8 A.M. and 6 P.M. subject to the condition that the supply is supplied only after the capacity of the substation is enhanced from 100 K.V.A. to 150 K.V.A. as it is nearly loaded.
	Signature of Licensee.
15. Remarks of Chief Electrical Inspector to Government on the essentiality of supply.	
16. Orders of the Chief Electric Inspector. (in case of Ty. supplies).	Signature of Chief Electrical Inspector to Government.
17. Orders of the Provincial Government.	

N.B:—Please communicate the order to the Resident Engineer, The Mangalore Electric Supply Co., Ltd., Mangalore.

S. P. Works, Ltd, M —13-1-50/300